



# MADHYA PRADESH POWER TRANSMISSION CO.LTD.

(A wholly owned Govt. of Madhya Pradesh Undertaking)

CIN: U40109MP2001SGC014880

Block No.3 Shakti Bhawan, Rampur, Jabalpur (M.P.)482008

Phone : (0761) 270-2162, 2238, 2134 Fax:(0761)2665593 e-mail:mptransco@nic.in

No. 04-01/TK-II/ADB-III/TR-501/LOT-1/

1245

Date: 11 FEB 2016

To,

M/s Bharat Heavy Electricals Ltd.  
Tower-A, 5<sup>th</sup> Floor, Advent Navis  
IT Business Park, Plot No. 7,  
Express Highway, Noida, UP

Fax No.-0120-6748579

**Sub:-** Construction of new 400 KV Substation, transmission lines and augmentation Work/feeder bay work on total turn key basis (Lot No. 1) against order No. 04- 01/ADB-III/MPPTCL/TR-501/LOT-1/TK II/06602-dtd.28/02/2014-

**Ref:** - Your letter No. TBEM/MPPTCL/TR-501/83012/LOT-1/Clamp/SK dated 08.12.2015

Dear Sir,

This has reference to your letter dated 08.12.2015 vide which you have submitted following drawings of Clamps and Connectors of M/s Exalt Engineering Industries make and requested us to approve the same.

SI No.	Drawing No.	Observation
1	EEl-3195R1A for 132 KV Bus post Isolator, Rigid through type connector suitable for twin Zebra ACSR conductor with horizontal approach	OK
2	EEl-3196 for 132KV Bus post Isolator, Rigid through type connector suitable for single Zebra ACSR conductor with horizontal approach	OK
3	EEl-3195R1B for 33 KV Bus post Isolator, Rigid through type connector suitable for twin Zebra ACSR conductor with horizontal approach	OK
4	EEl-3196A for 33 KV Bus post Isolator, Rigid through type connector suitable for single Zebra ACSR conductor with horizontal approach	OK
5	EEl-3347 220 KV two way PG Clamp suitable for single ACSR moose conductor	OK
6	EEl-3191 for 132 KV tee connector suitable for twin Zebra ACSR conductor	OK
7	EEl-3192 for 132 KV two way PG Clamp suitable for single ACSR Zebra conductor	OK
8	EEl-3192A for 132 KV two way PG Clamp suitable for single ACSR Zebra to single Panther Conductor	OK

9	EEl-3194 for 132 KV Rigid spacers for twin Zebra ACSR conductor	OK
10	EEl-3193 33 KV tee connector suitable for single Zebra ACSR run and single Zebra ACSR tap	OK
11	EEl-3192 C 33 KV PG Clamp suitable for single ACSR Zebra conductor	OK
12	EEl-3192 B 33 KV PG Clamp suitable for single ACSR Zebra to single Racocon conductor	OK
13	EEl-3194A for 33 KV Rigid spacers for twin Zebra ACSR conductor	OK

In this matter please note that these clamps should be manufactured by either pressure Die cast or Gravity die cast process. Subject to incorporation of above comments the above drawing are generally found in order and hereby approved. Copies of approved drawings duly stamped are enclosed herewith for further needful please.

Thanking You

Encl. As above

Yours sincerely,



Chief Engineer (Procurement) -

Copy to:-

1. The Chief Engineer (EHT-C) MPPTCL, Jabalpur.
2. The Chief Engineer (EHT-C-M&I) MPPTCL, Jabalpur, with one set of Drawing
3. The Superintending Engineer (EHT) Circle, MPPTCL, Bhopal/ Jabalpur/ Indore.
4. The Executive Engineer (EHT:C)Dn. MPPTCL, Bhopal/ Barwaha-II/ Ujjain with one set of Drawing.
5. The Executive Engineer (EHT:C) Dn.-I MPPTCL, Jabalpur with one set of Drawing